

FEES AND FINE AS PER THE EMERGENCY SERVICES BY-LAWS

FEES PAYABLE TO THE SERVICE IN TERMS OF SECTION 10 OF THE FIRE BRIGADE SERVICES ACT, 1987 (ACT 99 OF 1987) AS AMENDED, FOR PROVIDING EMERGENCY SERVICES

- 144** (1) A controlling authority may, subject to any condition contemplated in section 11 (2) (a) of the Fire Brigade Services Act, Act 99 of 1987, determine the fees payable by a person on whose Behalf the service of the controlling authority is applied –
- (a) For the attendance of the service;
 - (b) For the use of the service and equipment; or
 - (c) For any material consumed.
- (2) A person on whose behalf, in the opinion of the Chief Fire Officer concerned, a service of a controlling authority has been employed, may in writing be assessed by that Chief Fire Officer for the payment of the fees referred to in subsection (1) or any portion thereof;
- (3) The prescribed fees payable to the Service as determined in to these By-laws;
- (4) Any person who feels aggrieved by an assessment contemplated in subsection (2) may within 14 days after receipt of that assessment object in writing against that assessment as such or the amount thereof to the controlling authority concerned;
- (5) As soon as an objection contemplated in subsection (4) is received, that Chief Fire Officer of the controlling authority concerned shall without delay obtain written comment thereon and submit it together with the objection to the controlling authority, which may confirm, alter or revoke the assessment;
- (6) A certificate purporting to be signed by a Chief Fire Officer and in which it is certified that the assessment specified therein was made under subsection (2), shall on production thereof in a court of law be prima facie proof of the amount payable by the person mentioned therein;

Annexure XVIII

TARIFF OR CHARGES

Personnel Charges

No	DESCRIPTION	FEES
1	For each Fire Officer, per hour or part thereof	R55.00
2	For each Firefighter, per hour or part thereof	R33.00

Use of Vehicles Per Hour or Part Thereof

NO	DESCRIPTION	FEES
1	Hydraulic Platform	R110.00
2	Heavy Duty Pump Unit	R82.50
3	Medium Duty Pump Unit	R66.00
4	Light Duty Pump	R55.00
5	Rescue Unit	R66.00
6	Water Tanker	R77.00
7	Service Vehicle	R33.00
8	Mobile Control Unit	R99.00
9	Portable Equipment	R22.00

- a. Vehicle call out fees will be charged per hour per Vehicle, and
- b. R5.50 for each kilometer traveled;
- c. Use of chemicals, equipment and other means: The actual cost plus 10%
- d. Use of water: The water tariff as determined by the Council from time to time by Special Resolution in terms of the Water Supply By-laws.
- e. Special services per hour or part thereof, per vehicle: In terms of section 3(a) to 3(d).
- f. Refill of oxygen-and diving cylinders: per Cylinder R22.00.

Plan Approval for Flammable Substances

NO	DESCRIPTION	FEES
1	Liquefied Petroleum Gas	R500.00
2	Flammable Liquids	R500.00
3	Flammable Liquids Store, Spray Booth and Dry Clean	R500.00

Tariffs for Inspection and Issuing of Certificates and Permits

NO	DESCRIPTIONS	FEES
1	Building Compliance Certificate	R500.00
2	Event Safety Compliance Certificate	R500.00
3	Spray Booth/Room Permit	R275.00
4	Dry Cleaners Permit	R275.00
5	Handling of Hazardous Substances	
5.1	Bulk Depot Certificate of Registration	R500.50
5.2	Storage and/or use of LPG Containers	R500.00
6	Fireworks Compliance Letter	
6.1	Dealing in Fireworks (500kg)	R500.00
6.2	Dealing in Fireworks (1000kg)	R500.00
6.3	Display of Fireworks	R500.00

Fines for Transgressing Activities

NO	DESCRIPTION	FEES
1	1 st transgression	R 253.00
2	2 nd transgression	R 506.00
3	Thereafter	R 1518.00

GENERAL DIRECTIVES FOR THE PAYMENT OF THE FEES

- 145** (1) All certificates of registration, certificates of compliance and transport or spraying permits will
Be valid for twelve calendar months. A written application for the renewal of the certificate or permit must reach the Service at least one calendar month prior to the expiry thereof.
- (2) When application is made for registration, the appropriate application form, correctly completed in full, must be accompanied by the prescribed fees.
- (3) All the appropriate application forms are available from the Service and must be completed in full and, where applicable, be duly signed.
- (4) If, for whatever reason, the Service rejects an application for any certificate of registration, certificate of compliance or any permit, the applicant must, within 14 days (excluding weekends and public holidays) of the date of rejection, take corrective steps to ensure that the document in question is issued at no additional cost, failing which the applicant must pay the prescribed fees again.
- (5) If there are different divisions and/or affiliates within a business and/or company situated on the same premises but each division and/or affiliate is managed separately, each division and/or affiliate is liable to registration separately.

EXEMPTION FROM PAYMENT OF CHARGES

- 146** (1) No Charges shall be payable where –
- a. false alarm has been given in good faith;
 - b. the services were required as a result of civil commotion, riot or major incident/natural disaster;
 - c. the services were rendered in the interest of public safety;
- (4) The Chief Fire Officer is of the opinion that the services were of purely humanitarian nature or were rendered solely for saving life;

FINES

OFFENCE CODE	SECTION CONTRAVENED	DESCRIPTION OF OFFENCE	FINE
	9(3)(a) to (d)	Failing to comply with the remedial action set forth by controlling authority.	R5000
	9(4)	Failing to bear the cost.	
	10(1)	Failure to allow controlling authority to conduct an investigations.	R5000
	11	Failure to comply with a notice issued by the controlling authority.	R5000
	15(1)	Failure to report any fire hazards and other threatening danger to the service.	R5000
	16(1)(2)	Illegitimate wearing of fire services uniform or any other way masquerade as a member of the fire services. (impersonating to be a member of the services)	R5000
	17(1)	Illegitimate use of Identification certificate of a member.	R5000
	18(3)	Failure to allow member of service to seal off any building, closing street for public safety or effective firefighting.	R5000
	18(4)(b)(i) to (v)	Failure to allow member of service to exercise his or her powers as set forth in the Criminal Procedure Act (Act No 51 of 1977) as amended.	R5000
	20(1)	Failure to submit building plans for approval.	R5000
	20(2)	Failure to pay prescribed fee for the approval of the plan.	R5000
	20(4)	Commencing with construction work on site without an approved plan.	R5000
	20(4)	Failing to avail approved plans on the site for the duration of constructions for inspection by the service.	R5000
	21(1)	Failing to comply with the requirement of the existing premises.	R5000
	21(2)(a)(b)	Making addition, alterations on an existing premises without an approved plan.	R5000
	22(2)	Failing to design and construct building to allow drainage of water used during fire extinguishing.	R5000
	22(3)(a)(b)	Building or erecting a Low or High voltage transformer room on any level other than ground level.	R5000
	22(4)	Installing sprinkler system without a plan, design, following the guidelines and not consulting the service.	R5000
	23(1)	Failing to comply with the minimum engineering requirements.	R5000
	23(2)(a)(b)(c)	Failing to consult with the relevant departments before designing and construction of landfill site.	R5000
	24(1)(2)(3)	Failing to apply to the service for the erection of a temporary structure or tent for event or public gathering.	R5000
	24(4)	Using the certificate for an extended duration of the event or gathering.	R5000
	24(6)	Using the certificate for other premises or structure rather than the one was issued for.	R5000
	24(8)(a)(b)(c)(d)	Failing to submit an application to the service for fire safety inspection.	R5000

	24(9)(a)(i)(ii)(iii)(iv) (b)(i)(ii)(iii)(iv)	Failing to submit an application with the required documents.	R5000
	24(10)	Failing to use flame resistant or flame retardant materials.	R5000
	24(11)	Failing to arrange an inspection with the controlling authority after the structure has been erected.	R5000
	24(11)(i)(ii)(iii)	Failing to submit additional documents after completing the structure.	R5000
	24(12)(a)(b)	Failing to provide a clear safety distance required by this By-law.	R5000
	24(12)(c)(i)(ii)(iii)(iv)	Failing to comply with National Building Regulation T1.	R5000
	24(12)(d)	Population density of the structure not complying with National Building Regulation A21.	R5000
	24(12)(e)(f)	Allowing cooking and open fire in a tent.	R5000
	24(12)(g)	Failing to ensure that no open flame or fire is permitted as required by these By-law.	R5000
	24(12)(h)	Failing to place symbolic safety signs in a tent.	R5000
	24(12)(h)	Allowing people to smoke in a tent.	R5000
	24(12)(i)	Failing to install lighting and wiring according to the required standard.	R5000
	24(13)	Failing to supply controlling authority with additional requirement.	R5000
	25(1)(a) to (e)	Failing to comply with the requirement for the design and construction of structures stipulated in these By-law.	R5000
	25(1)(f)	Failing to comply with the requirements to design and construct a rational design as contemplated by the National Building Regulations.	R5000
	25(2)(a)(b)(c)(d)	Failing to design and construct hangars or halipads to drain, channel any liquid as required by these By-law.	R5000
	26(1)	Failing to comply with the relevant legislations.	R5000
	26(2)	Failing to consult with the relevant departments.	R5000
	27(1)	Failing to maintain a fire door and assemblies in accordance with the requirements.	R5000
	27(2)	Keeping the fire door open without automatic releasing hold-open-device.	R5000
	27(3)(a)(b)(c)(d)(e)(f)	Rendering or causing a fire door and assembly less effective.	R5000
	28(1)	Failing to comply with the requirements of emergency exit and escape routes.	R5000
	28(2)	Failing to fit a locking device approved by the controlling authority.	R5000
	28(3)	Failing to indicate an escape routes and doors with clear and approved symbolic safety signs.	R5000
	28(4)(a)(b)	Failing to ensure that escape door is fitted with the required hinges and locking devices.	R5000
	28(5)(a)(b)	Failing to comply with the requirements for doors in a feeder route.	R5000
	28(6)	Failing to provide an alternative means of escape when feeder route is locked.	R5000
	28(7)	Failing to ensure that escape routes are not obstructed.	R5000
	29(1)	Failing to comply with the requirements to design, construct and install extractor fans.	R5000

	29(2)	Failing to maintain an extractor fan system in accordance with the requirements.	R5000
	29(3)	Failing to ensure that installed extractor fans does not pose fire hazards to any property.	R5000
	30(1)	Failing to design and install sprinkler system in accordance with the requirements.	R5000
	30(2)(a)(b)	Failing to comply with the design, construction or installation requirements of a sprinkler system.	R5000
	31(1)	Failing to provide and install portable fire extinguisher on premises or buildings.	R5000
	31(2)	Authorizing a person without a permit or certificate to do maintenance on portable fire extinguishers.	R5000
	31(3)	Failing to comply with the instruction of the controlling authority to have appliance tested and inspected.	R5000
	31(4)	Failure to ensuring that you're issued with a certificate of compliance.	R5000
	32(1)	Failing to ensure that sufficient water supply for fire-fighting purposes is designed when developing a township.	R5000
	32(3)	Failing to ensure that fire hydrants are plotted on a plan in accordance with the requirements when developing a township.	R5000
	32(4)	Failing to adapt water reticulation from any risk area to high risk category.	R5000
	32(5)	Failing to ensure that fire protection plans for the premises to be connected are approved by the controlling authority.	R5000
	32(5)(a)	Failing to calculate and design water supply for each sprinkler installation and size, delivery pressure and flow must be calculated by the responsible engineer.	R5000
	32(5)(b)	Failure to provide the premises with larger water supply for fire-fighting equipment in accordance with the requirements.	R5000
	32(5)(c)	Failing to ensure that size, work pressure and flow are calculated and designed in accordance with the requirements.	R5000
	32(5)(d)	Obtaining water connection to water reticulation system without fire protection plan been approved.	R5000
	32(6)(i)	Failing to ensure that storage capacity and rate of replenish of reservoir supplying water to the township is sufficient for fire-fighting purposes.	R5000
	32(6)(ii)	Failing to ensure that water supply to any area in the township can be provided from more than one direction.	R5000
	32(6)(iii)	Failing to install double supply main and double pumps.	R5000
	33(1)(a)(b)	Failing to apply for certificate of compliance for erecting any public building or temporary structure.	R5000
	36(2)	Failing to keep the certificate on the premises for inspection.	R5000
	36(3)	Failing to notify the service in writing of the change of the premises trade name.	R5000
	36(4)(a)(b)(c)(d)(e)	Failing to comply with the provisions of certificate or permit.	R5000

	37(1)	Failing to renew a certificate or permit.	R5000
	38(1)(c)	Giving false information on an application form.	R5000
	38(1)(d)	Making an incorrect or false statement in placards affixed.	R5000
	38(1)(f)	Performing any act or duty under these By-law in a negligent manner.	R5000
	38(1)(h)	Causing a severe breach of a permit or certificate issued to an operator.	R5000
	38(1)(g)	Changing anything relating or in connection with the premises for which a certificate or permit has been issued.	R5000
	39(1)	Failing to apply for the replacement of certificate or permit.	R5000
	40(3)	Failing to apply for a transfer of certificate.	R5000
	41(1)	Failing to apply for amendments of certificate or permit.	R5000
	42(1)(a)(b)(c)	Failing to plan, design and construct access to premises for fire and rescue appliances for fire-fighting and rescue purposes.	R5000
	42(2)(a)(b)	Failing to comply with the requirements for easy identification of premises number and maintenance thereof.	R5000
	43(1)(a)(b)	Failing to remove all combustible material, lock, and barricade or secure windows of vacant building.	R5000
	44(1)	Denying a member of service an access to the premises for inspection.	R5000
	44(2)(3)(4)	Failing to adhere to notice, orders, instructions and directives of a member to reduce fire risk or remedy the situation.	R5000
	44(5)	Failing to inform the chief fire officer about the measures he or she intends to take to rectify the condition.	R5000
	44(6)	Failing to meet the deadline set forth by the chief fire officer.	R5000
	45(1)	Failing to make access to firefighting equipment and mitigating agent.	R5000
	46(1)(a)(b)(c) (d)(e)(f)(g)	Failing to ensure that all fire-fighting equipment and mitigating agent are serviced and maintained.	R5000
	46(2)(a)	Failing to certify in writing the functionality of the installed, repaired fire fighting equipment.	R5000
	46(2)(b)	Failing to furnish the owner of the premises with certificate of compliance.	R5000
	46(2)(c)	Failing to notify the service in writing about the fire equipment that can't be repaired to its functional state.	R5000
	46(3)	Failing to keep a comprehensive service record of all fire-fighting equipment.	R5000
	46(3)	Failing to keep a comprehensive service record of all fire-fighting equipment.	R5000
	46(4)	Removing or interfering with any fire-fighting or service installation at any premises.	R5000
	46(5)	Altering, damaging or render ineffective any fire-fighting equipment at any premises.	R5000
	47(1)(2)	Allowing a juristic natural person and without a permit or certificate to maintain firefighting equipment.	R5000
	47(3)(6)	Removing fire extinguisher for servicing without	R5000

		a replacement of a similar appliance.	
	47(4) 53(2)	Servicing fire extinguisher and fire protection systems on an unsafe area.	R5000
	47(5)	Altering with fire-fighting equipment.	R5000
	48(1)(a)(b)(c)	Failing to formulate an emergency evacuation plan for the premises.	R5000
	48(1)(c)(i)	Failure to revise and update emergency evacuation plan as when there are changes on the premises.	R5000
	48(1)(c)(ii)	Failing to keep and maintain documents for emergency evacuation plan.	R5000
	48(1)(c)(iii)	Failing to avail emergency evacuation plan and relevant documents in the control room for inspection by the service.	R5000
	48(1)(d)	Failing to identify a predetermined place of safety (assembly point) outside.	R5000
	48(1)(e)	Failing to test and keep records of emergency evacuation plan.	R5000
	48(1)(g)	Failing to install emergency evacuation plan box I a prominent position at the main entrance.	R5000
	49(1)	Failing to submit a plan for approval.	R5000
	49(4)	Failing to comply with the instructions from the service for remedial action in regard to non-compliance of the premises.	R5000
	49(5)	Failing to comply with the requirements of a compliance certificate issued for the premises.	R5000
	49(6)	Failing to display a compliance certificate on the premises.	R5000
	49(7)	Failing to prevent overcrowding during public gathering.	R5000
	50(1)	Holding a public gathering on temporary structure or building without compliance certificate.	R5000
	51(1)	Allowing hazardous substances to pollute the environment	R5000
	51(2)	Failing to report a spill or escape of any hazardous substances.	R5000
	51(3)	Failing to take measures to prevent pollution from occurring, continuing or recurring.	R5000
	51(4)	Failing to report hazardous substances incident to relevant department or authorities.	R5000
	51(5)	Failing to prevent hazardous substances to pollute or degradation of environment from occurring or recurring.	R5000
	51(6) 72(2)	Dumping or spilling of flammable substances in unauthorized places.	R5000
	51(7)	Failing to inform and educate employees about the environmental risks.	R5000
	52(1)(2)	Failing to test and maintain fire protection systems.	R5000
	52(3)	Failing to inform the owner or person in charge in writing of any defect discovered.	R5000
	52(4)	Failure of the owner or person in charge to notify the controlling authority.	R5000
	52(5)	Failure of the owner or person in charge to provide alternative equipment to maintain the level of safety.	R5000
	52(6)	Failures of the owner or person in charge to let fire protection systems are examine or serviced.	

	52(7)	Failing to furnish the chief fire officer with a service record of fire protection systems.	R5000
	52(8)	Failing to issue the owner or person in charge with the certificate of compliance.	R5000
	53(1)(a)	Failing to notify the occupants of the testing of fire protection systems.	R5000
	54(4)(5)	Unauthorized removal, defacing, altering, tempering, damaging, render less effective of fire alarms and hydrant.	R5000
	55(1)	Failure of the owner or person in charge to display escape routes plan in an occupancy.	R5000
	56(1)(a)(b)	Overloading and incorrect use of all electrical appliances.	R5000
	57(1)	Using of flame emitting devices that may pose a fire hazard.	R5000
	58(1)	Storing combustible materials in a manner that will pose a fire hazard.	R5000
	58(2) 60(1)(2)(a)(i)(ii) (iii)(iv)(b)	Overgrowing of vegetation on a premises to an extent that it may pose a fire hazard.	R5000
	58(3)	Failing to properly store and dispose combustible materials and refuse.	R5000
	58(4)(a)	Using sawdust to soak any flammable liquids.	R5000
	58(5)	Allowing soot or combustible materials to accumulate in chimney, flue or duct.	R5000
	59(1)	Making fire in a manner in which it poses a potential threat to any human being, environment and properties.	R5000
	59(1)(a)(b)(c)	Failing to use or making fire in an approved devices.	R5000
	59(2)	Burning of combustible materials and refuse without the permission from the service.	R5000
	60(4)(5)(a)(b)	Making fire breaks by burning without notifying Fire Protection Association Officer.	R5000
	61(1)	Failing to submit an application to the service for certificate of registration.	R5000
	61(4)(a)(b)(c)	Commencing and continuing with any activities on the premises intend to store, install hazardous substances.	R5000
	61(5)(a)(b)	Failing to submit an application to the chief fire officer without relevant documents.	R5000
	61(6)	Failing to install Material Safety Data Sheet in a prominent place on the premises.	R5000
	62(1)	Storing, use, handle any dangerous goods without a registration certificate issued by chief fire officer.	R5000
	63(1)	Storing, handle of any dangerous goods on unregistered premises.	R5000
	63(1)(a)	Allowing dangerous goods or fumes of substances to come in contact with any fire, lames or naked light.	R5000
	63(1)(b)	Obstructing the escape of human being and animals.	R5000
	63(1)(c)(d)(e)	Failing to comply with the safety precautions of storing and handling of dangerous goods.	R5000
	72(1)(a)(b)	Performing any act that may cause fire, explosion and obstruct the escape to safety of human beings and animals.	R5000
	72(2)	Dumping of any dangerous substances into	R5000

		rivers, sewer, drains and borehole.	
	72(4)	Failing to comply with the safety distance.	R5000
	72(5)	Failing to comply with the use of dangerous goods in any basement level in the building.	R5000
	72(6)	Failing to comply with the requirement of the filling of a bus tank fuel and transport of any dangerous goods.	R5000
	73(1)(a)	Failing to comply with the requirement for equipping premises with portable fire extinguishers.	R5000
	73(1)(b)	Failing to comply with the requirement for equipping premises with fire hose reels.	R5000
	73(1)(c)	Failing to comply with the requirement for equipping premises with fire hydrants.	R5000
	73(1)(d)	Failing to comply with the requirements for equipping premises with sprinkler systems.	R5000
	73(3)	Failing to indicate fire-fighting equipment with a symbolic safety signs.	R5000
	73(4)(i)(ii)(iii)	Failing to supply extra fire-fighting equipment as requested by the controlling authority.	R5000
	74(1)(a)	Supplying of more quantity of dangerous goods to any unregistered premises.	R5000
	74(1)(b)	Delivering and supplying more dangerous goods than the quantity specified in the certificate of registration.	R5000
	74(2)	Failing to comply with the requirements of handling containers containing dangerous goods.	R5000
	74(3)	Supplying flammable substances to the premises that are not in possession of certificate of registration.	R5000
	74(4)	Failing to issue Material Safety Data Sheet to the storage facilities that are supplied with hazardous substances.	R5000
	75(1)(a)(b)(c)(d)(e)(f)(g)	Failing to comply with the requirements of delivering dangerous goods to a supplier.	5000
	75(2)	Failing to use a device that is designed for the specific purpose and in good working condition.	R5000
	75(3)	Failing to take reasonable precautionary measures to avoid spillage of dangerous goods during delivery	R5000
	75(4)	Failing to comply with the requirements of transferring dangerous goods from one vehicle, ship, and boat to another.	R5000
	75(5)	Failing to comply with the requirements of transferring dangerous goods to an aircraft.	R5000
	76(1)(2)	Failing to notify the service and relevant departments about the changes you intend to make on the premises.	R5000
	76(4)	Erecting a new structure on the premises after demolition took place without an approved plan.	R5000
	76(5)	Failing to apply for certificate of compliance and registration certificate for a new structure on the premises.	R5000
	77(1)	Failing to submit a plan with an application for a temporary certificate of registration to the service.	R5000
	77(2)(a)(b)(c)(d)	Failing to comply with the requirements of requiring more quantity of dangerous goods on	R5000

		the premises.	
	77(3)(a)(i)(ii) (b)(c)(d)(e)(f)	Failure to comply with the requirements of an approved application for temporary storage tank.	R5000
	78(1)	Failure to submit a plan for approval for permanent above and underground storage tanks.	R5000
	78(3)	Failure to ensure that storage tanks pumps, dispenser and pipework comply with the relevant codes.	R5000
	78(4)	Failure to ensure that a risk assessment is conducted.	R5000
	78(5)(i) (ii)(iii)(iv)	Failing to ensure that all safety precautions are put in place for the premises.	R5000
	79(1)	Failing to comply with the requirements to store, handle and install and liquid petroleum gas.	R5000
	79(3)	Failing to inspect and test the installation.	R5000
	79(4)	Failure to send a copy of certificate of conformity to the chief fire officer or the service.	R5000
	79(6)(i) (ii)(iii)(iv)	Failing to comply with the requirement of installing liquid petroleum gas in a building.	R5000
	79(7)	Placing fixed liquid petroleum gas installation in a garage.	R5000
	79(8)(i) (ii)(iii)	Failing to comply with the requirement for outdoor installation of liquid petroleum gas.	R5000
	79(9)	Installing liquid petroleum gas directly under the eaves of thatched roof.	R5000
	79(10)	Failing to comply with the safety distance for installing liquid petroleum gas.	R5000
	80(1)	Failing to comply with the requirements to, store, install and handle liquid petroleum gas in mobile units.	R5000
	81(1)	Failing to comply the requirements with store, install and handle bulk storage vessel for liquid petroleum gas.	R5000
	81(2)	Failure to submit a plan for approval for the installation.	R5000
	81(3)	Failure to ensure that risk assessment is conducted.	R5000
	81(4)	Failure to send a copy of conformity certificate to the chief fire officer or the service.	R5000
	82(1)	Failing to comply with the requirements for storage and filling premises for liquid petroleum gas.	R5000
	82(2)	Failing to submit an application forms.	R5000
	83(1)(i) (ii)(iii)	Failing to comply with the requirements of container handling and storage safety precautions.	R5000
	83(2)	Failing to label and mark the container containing flammable substances.	R5000
	83(3)	Failing to comply with the requirements to extract flammable liquids from a container.	R5000
	83(4)	Failing to store empty flammable liquid in a storeroom.	R5000
	83(5)(i)(ii) (iii)(iv)(v)	Failing to comply with the requirements for open air storage of any empty flammable containers.	R5000
	83(6)	Failure to comply with the requirement contemplated in section 61 and 62 of the By-laws.	R5000
	83(7)	Failure to make provision of additional escape	R5000

		gate fitted with a sliding bolt or similar locking device.	
	83(8)		
	84(1)	Entering storage tank containing group III dangerous goods without wearing an effective suitable breathing apparatus.	R5000
	84(2)	Entering storage tank containing group III dangerous goods without a person attached to a rescue rope controlled by a responsible person.	R5000
	84(4)	Entering any storage tank containing flammable liquids without tank being declared gas-free.	R5000
	84(5)(i) (ii)(iii)	Performing hot-work inside the tank before the tank is inspected.	R5000
	85(1)	Failing to comply with section 76 of these By-laws.	R5000
	85(2)(i) (ii)(iii)(iv)	Failing to notify relevant Authorities within specified period of time of the cessation.	R5000
	85(3)	Failing to fill the underground tank with liquid cement slurry.	R5000
	86(1)	Using, dealing or discharging of fireworks without permit or certificate issued by the SAPS Chief Inspector of explosives.	R5000
	86(3)	Failing to apply to the chief fire officer or the service to use, deal or discharge any fireworks.	R5000
	86(4)(i)(ii)(iii)(iv)(v)	Failing to submit application with the required supporting documents.	R5000
	63(5)	Failing to submit application to the chief fire officer before time period set forth by the service.	R5000
	86(6)	Failing to notify the chief fire officer before opening and commence with fireworks day to day business.	R5000
	86(7)	Failing to comply with the conditions as indicated on the letter issued to the chief inspector of explosives.	R5000
	86(8)	Amending and transferring a letter issued to SAPS chief inspector of explosives.	R5000
	86(9)	Failing to sell fireworks in their original packages.	R5000
	86(10)	Walking around or traveling with fireworks not in their sealed original package.	R5000
	86(11)	Displaying fireworks on windows or any other place where fireworks can be interfered with by the public.	R5000
	86(12)(i)	Failure of the dealer to affixed notice reading "Dealer in Fireworks" at every entrance.	R5000
	86(12)(ii)	Failure of the dealer to affixed notice reading "No Smoking" inside the premises.	R5000
	86(13)(i)	Failing to take all precautions to prevent accident by fire.	R5000
	86(13)(ii)	Failing to prevent unauthorized persons to have access to fireworks.	R5000
	86(13)(iii)	Failing to abstain from any act that may cause fire.	R5000
	86(13)(iv)	Keeping flammable liquids together with fireworks.	R5000
	86(13)(v)	Failing to store fireworks 5 meters away from matches.	R5000
	86(14)	Smoking or taking naked light in the premises	R5000

		where fireworks are kept, handled or stored.	
	86(15)	Wholesale dealers keeping, handle and store more than 1000 kg gross mass of fireworks on the premises.	R5000
	86(16)	Supplying fireworks to unlicensed dealer by a manufacturer or wholesale dealer.	R5000
	86(17)(a)	Retail dealers keeping, handle and store more than 500 kg gross mass of fireworks on the premises.	R5000
	86(17)(b)	Retail dealer interferes with inner packing of fireworks or allow, permit to be interfered with.	R5000
	86(17)(c)	Fail to supply fireworks to the public in sealed inner packing as received from manufacturer or wholesale dealer.	R500
	86(17)(d)	Sell fireworks to a child or person under the age of 16 years.	R5000
	86(17)(e)	Failing to furnish each employee with a copy of chapter 9 of explosive Act (Fireworks Regulations).	R5000
	86(18)	Allows a child or person under the age of 16 years to handle or use fireworks without adult supervision.	R5000
	86(19)	Handling or attempt to handle fireworks while under the influence of intoxicating liquor or narcotics.	R5000
	86(20)	Selling of fireworks by street hawker/vendor or out of vehicle or from spaza shop.	R5000
	86(21)	Dealing in fireworks without a license issued by the Chief Inspector of Explosives.	R5000
	86(22)	Failing to keep records as prescribed.	R5000
	86(23)	Fireworks not packed and sealed as received from manufacturer or supplier.	R5000
	87(1)	Failing to apply to the controlling authority for firing fireworks.	R5000
	87(2)	Failing to submit application on time.	R5000
	87(3)	Firing, displaying fireworks without a confirmation letter from the council.	R5000
	87(4)	Presenting fireworks display in a premises not designated by the council.	R5000
	87(5)	Failing to comply with the terms and conditions of fireworks display permission.	R5000
	87(6)	Displaying fireworks on pavements, hawkers' spot.	R5000
	87(7)	Allowing or permitting a minor to light or ignite fireworks.	R5000
	87(8)	Failing to inform to the controlling authority of the public display of fireworks.	R5000
	87(8)(b)	Allowing any person under the age of 18 years and incompetent to use or firing fireworks.	R5000
	87(8)(c)	Failing to inform the controlling authority with the date and time of the display of fireworks.	R5000
	87(8)(d)	Failing to inform the controlling authority of the exact location planned for the display.	R5000
	87(8)(e)	Failing to disclose the age and qualification of the person to do the actual discharging of fireworks.	R5000
	87(8)(f)	Failure to disclose the number, kind and the value of fireworks to be discharge.	R5000
	87(8)(g)	Failing to inform the controlling authority of the	R5000

		manner and place of storage of fireworks prior to the display.	
	87(8)(h)(1) (i)(ii)(2) (3)(4)(5)	Failing to indicate to the controlling authority the diagram of the ground with safety measures on which the display is to be held.	R5000
	87(9)	Allowing a non pyrotechnician to present fireworks display.	R5000
	87(10)	Willfully entering on or remain in the area reserved for receiving falling residue from aerial fireworks.	R5000
	87(11)	Willfully proceed beyond the area demarcated by the organizers.	R5000
	87(12)	Using or discharging of any explosive or similar device that may cause a noise nuisance.	R5000
	87(13)	Displaying fireworks without a written permission from Chief Inspector of Explosives and local authority concerned.	R5000
	87(14)	Failing to supply the controlling authority with an indemnity to safeguard the public and the officials.	R5000
	87(15)	Failing to obtain a written permission from SAPS and send a copy to the local authority.	R5000
	88(1)(i)(ii)(iii) (vi)	Presenting fireworks display without authorization from relevant authorities.	R5000
	88(1)(iv)	Displaying fireworks without a supervision of a chief inspector of explosives.	R5000
	88(1)(v)	Displaying fireworks without the Fire Brigade services for standby.	R5000
	88(1)(vi)	Failing to comply with the minimum safety distance for launching of fireworks display.	R5000
	88(1)(vii)	Failing to ensure that no person is entering the fireworks display area.	R5000
	88(2)(i)	Displaying fireworks within 500 meters of explosive factory, petrol depot, storage or station.	R5000
	88(2)(ii)	Using, displaying or explode fireworks in any building or public thoroughfare.	R5000
	88(2)(iii)	Displaying fireworks on an agricultural holding.	R5000
	88(2)(iv)	Displaying fireworks on any public place.	R5000
	88(2)(v)	Displaying fireworks at any school, hospital, old age homes.	R5000
	88(2)(vi)	Displaying fireworks in a business district area.	R5000
	88(2)(vii)	Light or ignites fireworks at a place where animals are present.	R5000
	88(3)(a) to (j)	Failing to comply with the times and period of the day set forth by the controlling authority to display, lite or ignite fireworks.	R5000
	89(1)	Failing to place or provide symbolic safety signs to the storage of dangerous goods.	R5000
	90(1)	Failing to report any fire, accident or dumping of dangerous goods on unauthorized places.	R5000
	91(1)(a)	Failing to allow a member of service together with authorized person or company to take material or substances for sampling.	R5000
	91(1)(c)	Failing to pay the expenses incurred after taking samples.	R5000
	92(1)	Failing to handle, use, store and transport all group I dangerous goods in accordance with the relevant SANS code and other legislations.	R5000

	93(1)(2)	Failing to comply with the requirement to manufacture, mark, fill and storing of group II portable containers.	R5000
	93(3)	Failing to comply with the requirement for transporting group II portable containers.	R5000
	93(4)	Failing to comply with the requirement for designing, manufacturing of group II bulk containers.	R5000
	93(5)	Installing group II manifold indoor on any premises.	R5000
	93(6)(i)(ii)(iii)		
	93(8)	Failing to obtain permission from the chief fire officer to use, handle, display or apply any hydrogen-filled portable containers.	R5000
	93(11)(i)	Using acetylene welding devices indoor.	R5000
	93(13)(a)	Failing to supply fire hydrant with the required water supply.	R5000
	93(13)(b)	Failing to plot fire hydrant in parallel to pipeline at every pump station and keep them maintained.	R5000
	93(13)(c)	Failing to provide sufficient cathodic protection for the pipeline and keep it maintained.	R5000
	93(13)(d)	Failing to mark the pipeline and keep maintained.	R5000
	93(13)(e)	Failing to comply with the requirements of pipeline installation and extension.	R5000
	93(13)(f)	Failing to comply with the requirements of a pipeline construction.	R5000
	94(1)(2)	Failing to comply with the requirement to manufacture storage tanks.	R5000
	95(1)(b) to (h)		
	95(1)(a)		
	96(1)	Using any vehicle to transport dangerous goods without registering the vehicle as such.	R5000
	96(2)	Failing to comply with the requirements to obtain a permit for the transportation of dangerous goods.	R5000
	97(1)	Failing to submit an application for the transportation of dangerous goods.	R5000
	97(2)	Application submitted without the required documents.	R5000
	97(4)	Failing to bring the vehicle to the service for inspection to obtain permit.	R5000
	97(5)	Failing to submit additional information requested by the controlling authority.	R5000
	97(8)	Failing to submit registration documents to the Chief Fire Officer.	R5000
	98(1)	Failing to keep the dangerous goods transport permit and other dangerous goods document in a vehicle.	R5000
	100(1)	Allowing any vehicle to transport dangerous goods in excess of the permissible amount.	R5000
	100(2)	Supplying dangerous goods to an operator of a vehicle without a valid dangerous goods transport permit.	R5000
	100(4)(i)	Stopping and parking dangerous goods vehicle overnight in a business district area.	R5000
	100(4)(ii)	Left a dangerous goods transport vehicle unattended.	R5000

	100(4)(iii)	Operating, parking or driving in a residential, hospital' schools and old age home area.	R5000
	100(4)(iv)	Taking to trips with explosives without a permission from SAPS Chief Inspector of Explosives.	R5000
	101(1)	Failing to inform the controlling authority of the areas which the vehicle will pass.	R5000
	101(2)(i)	Failing to provide the information regarding the product to be transported.	R5000
	101(2)(ii)	Failing to provide information on the nature of the hazard present by the product.	R5000
	101(2)(iii)	Failing to inform the service of the intended route to be used.	R5000
	101(3)	Failing to comply with the alternative route recommended by the controlling authority.	R5000
	101(4)	Failing to inform the controlling authority at the start of the operation.	R5000
	101(5)	Failing to inform the controlling authority of discontinuation of the operation.	R5000
	108(2)(a)	Failing to provide storeroom of dangerous goods with symbolic safety signs.	R5000
	108(2)(b)	Failing to indicate flammable substance group and their corresponding quantities outside the door.	R5000
	108(3)	Failing to comply with the conditions on the registration certificate.	R5000
	108(4)(a)(b) (c)(i)(ii)(aa)(bb)	Failing to comply with the requirements of the construction of any storeroom.	R5000
	108(5)	Failing to equip a storeroom with a fire door.	R5000
	108(5)(a)	Failing to comply with the requirement of the opening of the door and locking mechanism.	R5000
	108(5)(c)(i)(ii)(d)	Failing to comply with the requirement of the type of fire doors to be installed.	R5000
	108(6)(a)(b)(c)(d)	Failing to comply with the requirement of a window frame to be installed.	R5000
	108(7)(a)(b)(c)(d)	Failing to comply with the requirement to design and construction of a catch pit in the storeroom.	R5000
	108(8)(9)(10)	Failing to comply with the requirement to design and construct ventilation for the storeroom.	R5000
	108(9)(a)(b)	Failing to effectively naturally ventilate a storeroom as required by this subsection.	R5000
	108(10)(a)(b) (c)(d)(f)	Failing to install mechanism ventilation in accordance with the requirement of this subsection.	R5000
	108(11)(a)	Failing to protect and install all electrical apparatus, fittings and switchgear in any storeroom in accordance with SANS code.	R5000
	108(11)(b)	Failing to install all electrical equipment that does not comply with the provisions of SANS code outside the storeroom.	R5000
	108(11)(c)	Failing to effectively earth all metal parts and electrical fittings connected to the storeroom.	R5000
	108(11)(d)	Failing to place switches actuating any mechanical ventilation system outside the storeroom.	R5000
	108(11)(e)	Failing to switch on any mechanical ventilation system at all times during occupation.	R5000
	108(11)(f)	Failing to switch off all electrical apparatus and	R5000

		fittings.	
	108(12)	Failing to submit a certificate of compliance from a suitably qualified electrician to the chief fire officer.	R5000
	108(14)	Entering storeroom of dangerous goods without a permission from the person in charge.	R5000
	108(15)(a)	Using storeroom of dangerous goods for any purpose other than storing hazardous substances.	R5000
	108(15)(b)	Failing to comply with the requirement of performing any work in the storeroom.	R5000
	108(15)(c)	Storing or handling dangerous goods that obstruct the escape of persons and or animals during an emergency.	
	108(17)(i)(ii)	Failing to provide a storeroom with foam inlet and equipment	R5000
	109(1)(i)(ii)	Failing to comply with the requirement of storing any flammable substances.	R5000
	110(1)(i)(ii)	Failing to comply with the requirement of a use of a spray-painting room.	R5000
	111(1)	Failing to submit an application to the service for approval.	R5000
	111(3)	Failing to submit an application time and period set forth by the service.	R5000
	111(4)	Failing to invite the chief fire officer to the premises to conduct an inspection.	R5000
	111(5)	Failing to submit additional information requested by the controlling authority.	R5000
	111(7)	Failing to comply with conditions as indicated on the application.	R5000
	119(1)	Using or handle dangerous goods on an unregistered premises or spray-painting room.	R5000
	119(1)(a)	Failing to ensure dangerous goods fumes does not come into contact fire, flames or other source of ignition.	R5000
	119(1)(b)	Failing to ensure that escape routes are not hampered hindered in the event of fire or an emergency.	R5000
	119(1)(c)	Entering spray-painting room without authority from the owner, occupier or person in control.	R5000
	119(1)(d)	Using spray-painting room for any purpose other than spray-painting.	R5000
	119(1)(e)	Allowing any person to enter spray-painting room with mechanical ventilation system not operating.	R5000
	120(1)(a)	Failing to display permit, certificate for spray-painting room prominently in a weatherproof container on the premises.	R5000
	120(1)(b)	Failing to maintain and keep permit, certificate for spray-painting room legible at all times.	R5000
	121(1)(a)	Failing to construct a concrete floor of a spray-painting room.	R5000
	121(1)(b)	Failing to construct a wall of a spray-painting room with bricks and/or concrete.	R5000
	121(1)(c)	Failing to construct a reinforced concrete roof of a spray-painting room.	R5000
	121(1)(d)	Failing to provide a spray-painting room with the required fire door.	R5000
	121(1)(e)	Failing to provide a spray-painting room with the	R5000

		required window panels.	
	121(5)(a) (i)(ii)(iii)	Failing to comply with the requirements of the doors to be provided for spray-painting room.	R5000
	121(5)(iv)	Failing to provide a door with the required locking mechanism.	R5000
	121(6)(i)(ii)	Failing to ensure that spray-painting room is located separately from other activities.	R5000
	121(6)(a) (i)(ii)(iii)	Failing to ensure that any activity, processes posing fire danger adjacent to spray-painting room is prevented.	R5000
	121(6)(b)	Failing to comply with the requirements of constructing or erecting spray-painting room indoors or outdoors.	R5000
	121(7)(a)	Failing to comply with the requirement of water floors for spray-painting room.	R5000
	121(8) to (12)	Failing to comply with the requirements for installing all electrical apparatus, lights, fittings in accordance with SANS code.	R5000
	121(9)	Failing to comply with the requirements of all electrical switchgear, distribution boxes that are not in compliance with the provisions with SANS codes.	R5000
	121(10)	Failing to ensure that all switches actuating any mechanical ventilation system are situated outside spray-painting room.	R5000
	121(11)	Failing to earth all metal parts, electrical fittings and any device connected to spray-painting room.	R5000
	121(12)	Failing to submit a certificate of compliance for all electrical installation from a qualified and accredited electrician.	R5000
	121(13)(i)(ii)(iii)	Failing to equip spray-painting room with mechanical inlet and outlet ventilation system.	R5000
	121(13)(iv)	Failing to attach all ventilators firmly to the inside of the wall.	R5000
	121(13)(v)	Failing to affix bottom ventilators as close as possible to the level of the floor.	R5000
	121(13)(vi)	Failing to install all ventilation openings, air duct in the opposite wall, door or floor.	R5000
	121(13)(vii)	Failing to ensure that every spray-painting room is fitted with un-openable strengthen, shatterproof glass.	R5000
	121(14)(i)(ii)(iii)	Failing to comply with the requirements of a fire damper as indicated or provided in this section.	R5000
	121(14)(a)(i)(ii)	Failing to comply with the requirements of a sensor contemplated in this section.	R5000
	121(15)	Failing to comply with the requirements of positioning of ventilation outlet.	R5000
	121(16)	Failing to ensure that ventilation system is functioning whenever any activity takes place I a spry-painting room.	R5000
	121(17)	Spray-painting room not provided with symbolic safety signs.	R5000
	121(18)	Failure to maintain spray-painting room.	R5000
	121(19)	Entering spray-painting room without the express permission.	R5000
	121(20)(a)	Failing to ensure that spray-painting room is not abused.	R5000
	121(20)(b)	Allowing or permitting any person to work in a	R5000

		spray-painting room with mechanical ventilation system off.	
	121(20)(c)	Placing any obstructions, hindrance in the escape openings or in front of any door of a spray-painting room.	R5000
	121(21)(a)(b)(c)	Failing to provide firefighting equipment on the spray-painting room	R5000
	122(1)(a)(b)	Failing to comply with the requirements of the use of any dry-cleaning room.	R5000
	123(1)	Failing to apply to the controlling authority for dry-cleaning permit.	R5000
	123(3)	Failing to submit application to the service before time and period set forth by the controlling authority.	R5000
	123(4)	Failing to submit additional information requested by the controlling authority.	R5000
	123(5)	Failing to invite chief fire officer for inspection before dry-cleaning permit or certificate can be issued.	R5000
	124(1)(a)	Failing to construct a dry-cleaning room using class1 flammable liquids with bricks, concrete or similar non-combustible materials.	R5000
	124(1)(b)	Failing to ensure that all windows are glazed with wire-woven shatterproof glass.	R5000
	124(1)(c)	Failing to comply with the requirements of the doors to be fitted on dry-cleaning room using class 1 flammable liquids.	R5000
	124(1)(d)	Failing to comply with the requirements of a sill of a concrete to be fitted on dry-cleaning room using class 1 flammable liquids.	R5000
	124(1)(e)	Failing to comply with the minimum safety distance when constructing a dry-cleaning room.	R5000
	124(1)(f)	Failing to comply with the requirements of the doors to be fitted on a dry-cleaning room.	R5000
	124(1)(g)(i)(ii)	Failing to ensure that from a dry-cleaning room there is no opening into any other room or buildings.	R5000
	125(1)	Failing to comply with the requirements of constructing ventilation of dry-cleaning room using class I flammable liquids.	R5000
	125(4)(a)(b)	Failing to comply with the requirements of all exhaust ventilation ducts.	R5000
	125(5)	Failing to shut down the exhaust ventilating system after discovering a fire in a dry-cleaning room.	R5000
	126(1)(a)	Failing to construct a dry-cleaning room using class II flammable liquids with bricks, concrete or other non-combustible materials.	R5000
	126(1)(b)	Failing to comply with the requirements to erect a still of concrete for dry-cleaning room using flammable liquids.	R5000
	126(1)(c)	Failing to provide doors as required by this section.	R5000
	126(1)(d)	Constructing a dry-cleaning room below or above any other room or part of the building.	R5000
	127(1)	Failing to comply with the requirements of ventilation of dry-cleaning room using class 2 flammable liquids.	R5000
	129(1)(a)	Failing to display permit, certificate for dry-	R5000

		cleaning room prominently in a weatherproof container on the premises.	
	129(1)(b)	Failing to maintain and keep permit, certificate for dry-cleaning room legible at all times.	R5000
	130(1)	Entering a dry-cleaning room without permission from the person in charge.	R5000
	130(3)	Failing to thoroughly instruct or give induction to all employees on hazards involve in the use of flammable liquids.	R5000
	130(4)	Failing to provide a dry-cleaning room with an approved symbolic safety signs.	R5000
	131(1)	Failing to place machinery near to the exhaust ventilation duct in accordance with these By-law	R5000
	131(2)	Failing to comply with the requirements any machinery driven by a power shaft from motive power outside dry-cleaning room.	R5000
	131(3)	Failing to drain all dry-cleaning machinery on or above floor level.	R5000
	132(1)(a)(b)	Failing to comply with the requirement of fitting a dry-cleaning room steam pipe.	R5000
	132(2)	Failing to maintain a steam pipe.	R5000
	132(3)	Failing to comply with the requirements of steam supply system of a dry-cleaning room.	R5000
	133(1)(a) (b)(c)(d)	Failing to comply with electrical equipment installation to the dry-cleaning room.	R5000
	133(2)	Failing to use the safe or the required light, lamp when entering any dry-cleaning room.	R5000
	133(3)	Failing to ensure that the correct hand truck or trolley is used to convey any material or clothing.	R5000
	133(4)	Failing to comply with the requirement to install dry-cleaning machinery.	R5000
	134(1)	Failing to comply with the requirements storage tank connected to the dry-cleaning machinery.	R5000
	135(1)	Failing to comply with the requirement of installing boilers.	R5000
	136(1)(a)(b)	Failing to comply with the requirements of washing or brushing any material	R5000
	136(2)	Failing to examine any clothing or textile for article or objects like matches, metallic substances and items that can course sparks.	R5000